



**DEPARTMENT OF BUILDINGS**  
**CITY OF CHICAGO**

**COMMITTEE ON STANDARDS AND TESTS**

January 19<sup>th</sup>, 2017

**Attn:** Terron Wright  
Interplan  
1S280 Summit Ave # D4,  
Oakbrook Terrace, IL 60181

**Re:** Committee on Standards and Tests

**Issue:** The use of vent less cooking hoods as manufactured by Wells Manufacturing for the Muscle Maker Grill located at the ground floor of 111 West Jackson Street.

**Case:** 2017\_1A

Dear Terron Wright,

In response to your January 18<sup>th</sup>, 2017 appeal to the Committee on Building Standards Tests for the use of vent less cooking hoods model # WVU-96 by Wells Manufacturing at the Muscle Maker Restaurant located at 111 West Jackson, the Committee has voted to Approve your request as presented.

This approval is subject to the following requirements:

1. A technical presentation and seminar on this specific model of ventless cooking hood shall be provided to inspectors and plan reviewers from the Department of Buildings Ventilation Bureau prior to the installation of the hood at 111 West Jackson.
2. A Technical representative from Wells Manufacturing shall be present at the jobsite to demonstrate the operation of the hood and the required safety features when the cooking hoods are being inspected by the Department of Buildings Ventilation Inspectors.
3. The hood shall be installed and maintained in conformance with the manufacturer's instructions and the products testing and listing.

A copy of this approval letter shall be kept at the jobsite for review by the ventilation department.

Very truly yours,

Robert Fahlstrom  
Manager of Regulatory Review  
Chair of the Committee of Standards and Tests  
For Judith Frydland, Commissioner



**DEPARTMENT OF BUILDINGS**  
**CITY OF CHICAGO**

**COMMITTEE ON STANDARDS AND TESTS**

January 27<sup>th</sup>, 2017

**Attn:** Mr. Chris Chwedyck  
The Code Group  
111 West Washington Street  
Chicago, Illinois

**Re:** Committee on Standards and Tests

**Issue:** Use of a Ventless Type I Cooking Hood.

**Case:** 2017\_1B

Dear Chris Chwedyck,

In response to your, January 18<sup>th</sup>, 2017 appeal to the Committee on Building Standards Tests, for the use a Type 1 - Ventless cooking hood (Giles-Model #FSH-3.5) to be located on the 14<sup>th</sup> floor Offices of Home Chef to be located at the Wrigley Building 400-410 North Michigan Avenue, the Committee has voted to approve your request.

This approval is subject to the following requirements:

1. The HVAC system serving the Home Chef break area with the cooktop shall be designed to provide for outside air, sufficient exhaust and other measures as required to remove cooking odors. These features shall be provided by building ownership when the Giles hood is in operation.
2. The hood shall be installed and maintained in conformance with the product testing and listing and the manufacturer's installation and maintenance instructions.
3. A technical or sales representative from the Giles Company shall provide training to the Department of Buildings Ventilation Bureau about the installation, operation and maintenance of the Giles ventless cooking hood.



**DEPARTMENT OF BUILDINGS**  
**CITY OF CHICAGO**

All other Building Code requirements shall be met. This installation is site specific and shall not be viewed as a precedent. A permit is required for this work. A signed hard paper copy of this communication will be mailed to you at a later date. Please contact your project administrator for further assistance.

Very truly yours,

Robert Fahlstrom  
Manager of Regulatory Review  
Chair of the Committee of Standards and Tests  
For Judith Frydland, Commissioner